



**ADDENDUM #1
Facility Upgrades – North Prairie Substation
Waukesha County**

Date: December 7, 2004

Subject: Addendum #1 – Facility Upgrades North Prairie Substation – Waukesha County Project No. 5-87628 – STS Project No. 5-87628

Distribution

1. Plan Holders Registered with Badger Blueprints (via facsimile)

Addenda

Drawings: Detail 1/C-2 and Detail 2/C-3

Delete from Detail Notes:

Install 4" 316 SS gate valve with salt-resistant seals, shroud and stem riser accessible through bolt-down hand access way, Dezurik or equal. Submit with bid.

Add to Detail Notes:

Install 4" Dezurik Eccentric Plug Valve, cast iron soft rubber-lined body, flange connection with chloroprene plug, buried rated operator, extended nut for gear operator and valve box or equal. Include Tee wrench. (PEC, 4, F1, CIS, NBR, CR*GB-6-HD8, ENGS, VB635) Submit alternate with bid.

END OF ADDENDUM #1

Kevin L. Brehm, P.E.